



225 Stedman Street - #5  
Lowell, MA 01851  
Ph: 978-453-9191  
Fx: 978-453-1919

***Proposal for:***  
***Attn:***  
***Phone:***  
***Fax/Email:***

**NFPA25 requires annual testing and inspection of fire pump controllers.  
When was the last time your *Fire Pump Controller* was tested ?  
Is it fully operational? Are you complying with NFPA 25 ?**

***Rosemont Engineering, Inc.*** is the authorized  
service and sales representative for **ASCO/Firetrol, Inc.**  
We are committed to quality fire pump preventive maintenance !

In addition to your yearly flow test, we recommend an annual  
or semi-annual fire pump controller inspection conforming to NFPA25 !

***BENEFITS:***

***Peace of mind*** knowing the Fire Pump Controller is fully operational...  
***Professional troubleshooting*** should a problem be discovered...  
***Prompt and efficient repair*** of the fire pump or jockey controller...  
***Common service parts in stock*** eliminating costly multiple service calls...

***WHAT WE DO:***

- Check automatic and manual start functions
- Check battery charger status/operation
- Verify alarm outputs and connections
- Verify block heater operation
- Verify proper crank start outputs on circuits 1 and 2
- Check and adjust system pressure settings
- Exercise AC input power switch; verify charger alarm
- Check and tighten all connection terminal points
- Verify minimum run time (or manual stop function)
- Inspect louver/air intake operation during run condition
- Provide written laminated report of findings
- Install new data disk; clear event/memory logs (Mark II systems)

***UNIT COST:***

***Last NFPA25 Visit:***

***prepared by:***            **Rick Dumont**  
***date:***